



# APPLICATION FOR APPEAL

**Saint Paul City Clerk**

310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

RECEIVED

JAN 23 2012

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR  Mail-In

**YOUR HEARING Date and Time:**

Tuesday, Feb 7, 2012

Time 1:30 P.M.

**Location of Hearing:**

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1451 Clarence St. City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Tony Swanson Email anthony.Swanson@STPHA.org

Phone Numbers: Business 651-298-4907 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Handwritten Signature] Date: 1-20-12

Name of Owner (if other than Appellant): Public Housing Agency of St. Paul

Address (if not Appellant's): 555 N. Wabasha Suite # 400 St. Paul, MN 55102

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

#5 1451 Bedroom S.W Side - MSFC 1026.1  
Request variance on openable height.

C: K. LYKSETT  
B. SHERRY

DEPARTMENT OF SAFETY AND INSPECTIONS  
Fire Inspection Division  
Ricardo X. Cervantes, Director




CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

January 11, 2012

BETTY LOU AUTHIER  
PUBLIC HOUSING AGENCY  
200 ARCH ST E  
ST PAUL MN 55130-4347



### FIRE INSPECTION CORRECTION NOTICE

RE: 1449 CLARENCE ST  
Ref. #111289  
Residential Class: B

Dear Property Representative:

Your building was inspected on January 11, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on February 13, 2012 at 11:00 A.M..

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

#### DEFICIENCY LIST

1. 1449 - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work will require a permit(s). Call DSI at (651) 266-8989.  
*B. SHERRY - PROVIDE DOCUMENTATION TO NANCY - REEV'D*
2. 1449 and 1451 - SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.  
*N. SCHMIOT - E-MAILED TO JAMES THOMAS 1-11-12. 20 (1449)*
3. 1451 - MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring.  
*K. LYKSETT - W/O # 6042430*

*K. LYKSETT - W/O # 6042442*

4. 1451 - NEC 440.13 - For cord-connected equipment such as room air conditioners, household refrigerators and freezers, drinking water coolers, and beverage dispensers, a separable connector or an attachment plug and receptacle shall be permitted to serve as the disconnecting means. The appliance must plug directly into a permanent outlet.

*FISH TANK*

*B. SHERRY - W/O # 6042431*

5. 1451 Bedroom S.W Side - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information. -Double hung windows . Openable height is 14inches . Openable width is 38 inches. Sill 44inches. Glazed 30inches in height by 35inches in width.

*B. SHERRY - PROVIDE DOCUMENTATION TO NANCY.*

- 1451 ← 6. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.


If you have any questions, email me at: [james.thomas@ci.stpaul.mn.us](mailto:james.thomas@ci.stpaul.mn.us) or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas  
Fire Inspector

Reference Number 111289

1451 Clarence



01/20/2012 11:20 am