



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

December 15, 2010

Robert Solstad
Dorglass Inc
6008 Culligan Way
Minnetonka MN 55345

VIA EMAIL: RobertS@dorglass.com

Re: Appeal of Window Permit for property at 833 Germain Street
File No. ALH 10-514

Dear Mr. Solstad:

This is to confirm that on December 9, 2010 Marcia Moermond, the Legislative Hearing Officer, reviewed the above-referenced appeal and recommended granting a 12 1/8-inch variance on the openable height of one casement replacement egress bedroom window which measured at 17 7/8 inches high by 23 1/2 inches wide.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Ryan Rehn (email)
Stephen Ubl (email)
Angela Teegarden (email)
File