



Fire Inspection Report

City of Saint Paul

Department of Safety and Inspections
375 Jackson Street – Suite 220
Saint Paul MN 55101-1806

Owner Name Pawan Himraj

Owner Address _____

City State Zip _____

Owner Phone 763-486-9879

License _____

Complaint _____


C of O _____


Date 11/14/17

Building Address: 1032 Duluth St

You are hereby notified to remedy the conditions stated below immediately. A reinspection will be made after the reinspection date stated below. If you consider any of these code requirements to be unreasonable, you may appeal to the Legislative Hearing Officer. Applications for appeals may be obtained at the City Clerks Office, 170 City Hall 651-266-8989 within 10 days of the date of the original orders.

Code	Conditions to be Corrected
	Building is condemned with an immediate vacate due to fire damage
	Provide a 24 hour fire watch until fire alarm system is restored

Owner or Representative Signature 

Occupancy Type _____ Inspector Signature 

CFO Key _____ Reinspection Date _____

** For further information on this report, contact the Fire Inspection Division at 651-266-8989 **