



# APPLICATION FOR APPEAL

NOV 22 2010  
CITY CLERK

**Saint Paul City Clerk**  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

<b>YOUR HEARING Date and Time:</b>
Tuesday, <u>12/7/10</u>
Time <u>1:30</u>
<b>Location of Hearing:</b>
Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 918 NEBRASKA City: ST. PAUL State: MN Zip: 55117

Appellant/Applicant: CHRIS HAILBERG CONTRACTOR Email CHAILBERG@PRIDEENERGY SOLUTIONS.COM

Phone Numbers: Business <sup>763</sup> 767-4944 Residence MA Cell 612-385-9597

Signature: [Handwritten Signature] Date: 11-19-10

Name of Owner (if other than Appellant): FINNA PITULENKO (Home owner)

Address (if not Appellant's): SAME AS ABOVE. APPEALED ADDRESS

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell 397-556-4708

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
  - Summary/Vehicle Abatement
  - Fire C of O Deficiency List
  - Fire C of O: Only Egress Windows
  - Code Enforcement Correction Notice
  - Vacant Building Registration
  - Other
  - Other
  - Other
- REQUESTING A VARIANCE ON TWO DOUBLE HUNG WINDOWS OF 3" ON THE HEIGHT.
- HOMEOWNER DOES NOT WANT TO DESTROY ARCHITECTURAL LOOK AND CHARACTER OF HER HOME WITH CASHEM WINDOWS.
- \*\* WINDOW UNITS ARE ON 1ST FLOOR.



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: 11/18/10

APPEAL PROPERTY ADDRESS: 918 Nebraska W

APPLICANT NAME: Chris Haliberg <sup>Contractor</sup> PHONE NUMBER: 612-385-9597

PERMIT NUMBER: 20 10 909178

TYPE OF WINDOW: Double Hung

NUMBER OF WINDOWS: 2 Bedrooms - 1 window each

TOTAL GLAZED AREA: 67 sq ft DIFFERENCE FROM REQUIRED AREA: +158 OK

WIDTH OF OPENING: 23" DIFFERENCE FROM REQUIRED OPENING: +3" OK

HEIGHT OF OPENING: 21" DIFFERENCE FROM REQUIRED OPENING: -3"

HEIGHT OF OPENING TO FINISHED FLOOR: 28" DIFFERENCE FROM MAXIMUM HEIGHT: +20" OK

COMMENTS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

FROM: David Turk