



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

RECEIVED

OCT 04 2010

RECEIVED

CITY CLERK

OCT 04 2010

1. Address of Property being Appealed: <u>1369 Avon St. N</u>	2. Number of Dwelling Units: <u>Single Family</u>	3. Date of Letter Appealed: <u>9-29-10</u>
--	--	---

4. Name of Owner: Mona Koebcke
Address: 1369 Avon St N City: St. Paul State: MN Zip: 55113
Phone Numbers: Business _____ Residence 651-489-2019 Cellular _____
Signature: _____

5. Appellant / Applicant (if other than owner): Renewal by Andersen
Address: 1920 W City Rd C City: Roseville State: MN Zip: 55113
Phone Numbers: Business 651-264-4088 Residence _____ Cellular _____
Signature: Bryan Horton

6 State specifically what is being appealed and why (Use an attachment if necessary):

We are appealing a 2 double hung windows that will not
comply w/ Egress Policy. Current opening dimensions fall
short by 1/8" in height and is exceeded in both operable width
and overall glazed area. These windows are main level windows
and the homeowner does not want a different operating
style. Please Approve.

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <u>10/1/10</u>	Fee Received: <u>25pd.</u>	Receipt Number:	Date of Hearing: <u>Oct 5. 1:30</u>
----------------------------------	-------------------------------	-----------------	--

Revised 4/23/2007



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 29, 2010

APPEAL PROPERTY ADDRESS: 1369 AVON ST N

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 10 904004

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

Total Glazed Area	13.7 sq. ft.	Difference from Required Area	+ 8.7 sq. ftl
Width of Opening	32 "	Difference from Required Opening	+ 12 "
Height of Opening	22 7/8 "	Difference from Required Opening	-1 1/8 "
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.