



APPLICATION FOR APPEAL

RECEIVED

MAY 10 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☐ Copy of the City-issued orders or letter which
are being appealed
- ☒ Attachments you may wish to include
- ☒ This appeal form completed

YOUR HEARING Date and Time:

Tuesday, May 22, 2012

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1260 Grotto St. N. City: St. Paul State: MN Zip: 55117

Appellant/Applicant: Window World Email mollym@windowworldmn.com

Phone Numbers: Business 651-770-9011 Residence _____ Cell _____

Signature: Molly McNamee Date: 5/8/12

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other
- ☐ Other
- ☐ Other



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 5/8/12

APPEAL PROPERTY ADDRESS: 12100 Grotto St. N. St. Paul, MN 55117
APPLICANT NAME: Window World PHONE NUMBER: 651-770-9011
Attn: Molly McGivane (customer Svc. Rep)

PERMIT NUMBER: _____

TYPE OF WINDOW: Double Hungs

NUMBER OF WINDOWS: 3 need variance

TOTAL GLAZED AREA: _____

DIFFERENCE FROM REQUIRED AREA: 2.5 square ft.

WIDTH OF OPENING: 23.21

DIFFERENCE FROM REQUIRED OPENING: meets egress

HEIGHT OF OPENING: 20.00

DIFFERENCE FROM REQUIRED OPENING: meets egress

HEIGHT OF OPENING
TO FINISHED FLOOR: _____

DIFFERENCE FROM MAXIMUM HEIGHT: _____

RECOMMENDATION (IF APPLICABLE): Homeowner wants to replace her windows but doesn't want arguments. The double hung window meets egress opening height & width but not area. We are requesting a variance to allow a double hung be allowed to be installed. I have included the specs of the window

FROM: Molly McGivane

Select a Model

(Model 0201)	
Excalibur Double Hung	
Top Sash Width	24.3750
Top Sash Height	25.1875
Bottom Sash Width	25.3750
Bottom Sash Height	26.1875
Top Glass Width	22.6875
Top Glass Height	23.5000
Bottom Glass Width	23.6875
Bottom Glass Height	24.5000
Screen Width	23.9375
Screen Height	26.4375
Top Sash Weight (Plus 5 lb)	20 lb
Top Balance Size (C.F)	10PK
Top Balance Size (Spiral)	21-7B
Bottom Sash Weight	16 lb
Bottom Balance Size (C.F)	8LG
Bottom Balance Size (Spiral)	25-6R
Egress Opening Width	23.2190
Egress Opening Height	20.0000
Egress Opening Area (sq.ft.)	3.2250

Min. W: 11	Max W: 52	
Min. H: 20	Max H: 84	Max Ul: 132

	Exact Size
Width: 27 5/8	27.625
Height: 53 1/2	53.5

Extrusion: << For Arch-Top Models Only

Opening:

Type:

Screen:

Glass:

☐ AC Sash Calculator