



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

December 15, 2010

Lawrence Walker
629 St. Anthony Ave
St. Paul, MN 55104

Re: Appeal of Re-inspection Fire C of O with Deficiencies for property at 818 Sherburne Avenue
File No. ALH 10-520

Dear Mr. Walker:

This is to confirm that on December 9, 2010 Marcia Moermond, the Legislative Hearing Officer, reviewed the above-referenced appeal and recommended granting a 4.5-inch variance on the openable height of the egress window in the rear bedroom on the 2nd floor and a 2-inch variance on the openable height of the egress windows in the front and side bedrooms on the 2nd floor.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Paralegal

c: Fire Supervisors (email)
Pat Fish (email)
File