

Other

APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

RECEIVED
DEC 28 2011
CITY CLERK

The City Clerk needs the following to process your appeal:	
\$25 filing fee payable to the City of Saint Paul (if cash: receipt number) Copy of the City-issued orders or letter which are being appealed Attachments you may wish to include This appeal form completed Walk-In OR Mail-In	YOUR HEARING Date and Time: Tuesday, / - / O - / Q
Address Being Appealed:	
Number & Street: 1852 La Crosse Aucity:	5t. Paul State: MN Zip: 55119
Appellant/Applicant: Tony Swanson Er	mail anthony. Swanson @ StPHA.org
Phone Numbers: Business <u>651-298-4907</u> Residence	Date: 12-27-11 Agency Of St. Paul
Address (if not Appellant's): 555 N. Wabasha	Suite # 400 St. Paul, MN 55102
Phone Numbers: Business Residence	Cell
What Is Being Appealed and Why?	Attachments Are Acceptable
Revocation of the Coro	dvooms-MSFC102b.1 ance on openable height.

C: B. SHERKY K. LYKSETT

DEPARTMENT OF SAFETY AND INSPECTIONS Fire Inspection Division Ricardo X. Cervantes, Director

SAINT PAUL AAAA CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806

 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi

December 15, 2011

BETTY LOU AUTHIER PUBLIC HOUSING AGENCY 200 ARCH ST E ST PAUL MN 55130-4347



FIRE INSPECTION CORRECTION NOTICE

RE:

1852 LACROSSE AVE

Ref. #111520

Residential Class: B

Dear Property Representative:

Your building was inspected on December 15, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A reinspection will be made after January 16, 2012.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

B. SHERRY - WO # 6042181

1. All bedrooms - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-19inches openable height. Sill 35inches. Glazed is 38inchs in height by 35inches in width. Openable width is 38inches

B. SHERRY-PROVIDE DOCUMENTATION TO NANCY.

2. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

B.L. AUTHIER

3. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas Fire Inspector

Reference Number 111520