

APPLICATION FOR APPEAL

RECEIVED Saint Paul City Clerk

MAY 0 4 20320 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102

CITY CLERK Telephone: (651) 266-8560

| \$25 filing fee payable to the City of Saint Paul | YOUR HEARING Date and Time: |
|---|---|
| (if cash: receipt number) | Tuesday, 5-15-12 |
| Copy of the City-issued orders or letter which | |
| are being appealed | Time_ 1:30 P.M. |
| Attachments you may wish to include | Location of Hearing: |
| △ This appeal form completed | Room 330 City Hall/Courthouse |
| Address Being Appealed: | |
| Number & Street: 611 Mt Curve Blvd City: | SI. PAUL State: MN Zip: 55116 |
| Appellant/Applicant: Renewal by Andersen | Email bryan horton Pandersencorp.com |
| Phone Numbers: Business <u>651-264-4088</u> Residence | |
| Signature: | Date: |
| Name of Owner (if other than Appellant): Barbara Wolf | |
| Address (if not Appellant's): UII Mt Curve Blud | |
| Phone Numbers: Business Residence | 7-699-2336 Cell |
| What Is Being appealed and why? | Attachments Are Acceptable |
| | • |
| | line 2 restaured and |
| | ling 2 replacement casement |
| □ Fire C of O Deficiency List | that will not comply w/ Egress are attached. The only |
| Fire C of O: Only Egress Windows | we arrange for only |
| | egress is to widen the opening |
| MAICH WITH TEACH | cire extensive construction. |
| Other Other | s not want Change style or |
| pay the before | ing the opening windows are |
| Or iginal | |
| □ Other | |



CITY OF SAINT PAUL INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK 15 KELLOGG BLVD. WEST 310 CITY HALL SAINT PAUL, MN 55102

PHONE: 651-266-8688 651-266-8574 FAX:

DATE: May 1, 2012

APPEAL PROPERTY ADDRESS:

611 MOUNT CURVE BLVD

APPLICANT NAME:

RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER:

651-264-4914

PERMIT NUMBER:

12 051476

TYPE OF WINDOW

Casement Double

NUMBER OF WINDOWS

| Total Glazed Area | 4.3 sq. ft. | Difference from Required Area | 7 sq. ft |
|--|-------------|----------------------------------|----------|
| Minimum 5 Square Feet | | · . | |
| Width of Opening | 17 6/8" | Difference from Required Opening | -2-1/4" |
| Minimum 20 Inches | | | |
| Height of Opening | 33 3/8" | Difference from Required Opening | +11 3/8" |
| Minimum 24 Inches | | | |
| Height of Opening to Finished Floor | Ok | Difference from Maximum Height | ok |
| Maximum 48 Inches for Existing Openings | | | |

COMMENTS:

Reviewed by:

DD 5-1-12