



APPLICATION FOR APPEAL

RECEIVED
APR 01 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul
(If cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 4-12-11

Time: 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 467 ARLington ave E City: St. Paul State: MN Zip: _____

Appellant/Applicant: Northland Home Ext. Email: Dennis@northlandhome.net

Phone Numbers: Business (651)464-0234 Residence (651)7246877 Cell _____

Signature: Dennis Potapenko Date: 3/28/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

replaced existing double hung windows with new double hungs. No alterations to the opening were made.

replaced windows same size and style as the original.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: March 7, 2011

APPEAL PROPERTY ADDRESS: 467 ARLINGTON AVE E

APPLICANT NAME: NORTHLAND HOME EXTERIORS

PHONE NUMBER: 651-464-1700

PERMIT NUMBER: 11 008981

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 3

Total Glazed Area Minimum 5 Square Feet	12.5 sq. ft	Difference from Required Area	+ 6.8 sq.ft.
Width of Opening Minimum 20 Inches	35 in.	Difference from Required Opening	+15 in.
Height of Opening Minimum 24 Inches	16.5 in.	Difference from Required Opening	- 7.5 in.
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	35 in.	Difference from Maximum Height	+13 in.

COMMENTS: All three windows (one in each bedroom) are the same size.

Reviewed by: Virgil Thomas