



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

RECEIVED
FEB 16 2011

CITY CLERK
walk-in

1. Address of Property being Appealed: 1889 PALACE AV	2. Number of Dwelling Units: 1	3. Date of Letter Appealed: 2-16-11
--	-----------------------------------	--

4. Name of Owner: KATHY KIRK

Address: 1889 PALACE AV City: ST. PAUL State: MN Zip: 55105

Phone Numbers: Business _____ Residence 651-698-3356 Cellular _____

Signature: Kathy Kirk

5. Appellant / Applicant (if other than owner): _____

Address: _____ City: _____ State: _____ Zip: _____

Phone Numbers: Business _____ Residence _____ Cellular _____

Signature: _____

6 State specifically what is being appealed and why (Use an attachment if necessary):

WANT TO REPLACE BEDROOM WINDOWS (OPENING SIZE OF 23.3" W X 20" H) WITH NO EGRESS WINDOWS

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <u>2/16/11</u>	Fee Received: <u>25PA</u>	Receipt Number:	Date of Hearing: <u>3/8/11</u>
----------------------------------	------------------------------	-----------------	-----------------------------------



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: February 16, 2011

APPEAL PROPERTY ADDRESS: 1889 PALACE AVE

APPLICANT NAME: THE WINDOW STORE HOME IMPROVEMENTS INC

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 11 016486

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 3

Total Glazed Area Minimum 5 Square Feet	10.8 sq. ft.	Difference from Required Area	+ 5.8 sq. ft.
Width of Opening Minimum 20 Inches	23.3"	Difference from Required Opening	+ 3.3"
Height of Opening Minimum 24 Inches	20"	Difference from Required Opening	- 4"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	NA	Difference from Maximum Height	NA

COMMENTS:

Reviewed by: B.H.