



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

March 15, 2011

James Kuktavy
557 Ottawa Avenue
St. Paul, MN 55107

Re: Appeal for property at 297 Goodrich Avenue
File ID #: ALH 11-351

Dear Mr. Kuktavy:

This is to confirm that the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 2-inch variance on the openable height of the egress windows in the first floor, north bedroom and the 2nd floor, north and east bedrooms and granting a 1.5-inch variance on the openable width of the egress window in the first floor, west bedroom.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

cc: Fire Supervisors (email)
Pat Fish (email)
File