



Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

(10/19/10
1:30 mtg.)

FACSIMILE TRANSMISSION
Cover Sheet and Transmittal Form

Date: 10/12/10
To FAX#: 6-8574

RECEIVED
OCT 12 2010
CITY CLERK

To: Mai Yang Paralegal

Location: Legislative Hearing Office
City of St. Paul

Sender: Bruce Noyes / Jim Hannareilly
St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1172 (Bruce Noyes)

Message:

Request for Egress Windows Non-Compliance Determination
Attachments: - Egress Windows Non-Compliance Determination Form
- MANUFACTURERS SPECIFICATIONS

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 10/12/10

APPEAL PROPERTY ADDRESS: 655 FULLER

APPLICANT NAME: SAINT PAUL PARKERY PHONE NUMBER: 266-1143 DANIEL
COUNTRY PUB & RESTAURANT
FOR OWNERS LARRY & KENNA PRATT 651-224-6661

PERMIT NUMBER: _____

TYPE OF WINDOW: DOUBLE-HUNG

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 8.34 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLIES

MIDTH OF OPENING: 21.2'' DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING: 22.1'' DIFFERENCE FROM REQUIRED OPENING: 1.9''

HEIGHT OF OPENING TO FINISHED FLOOR: LESS THAN 48'' DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____



Select a Model

(Model 0201)
Excaltur Double Hung

Top Sash Width	22.3750
Top Sash Height	22.4000
Bottom Sash Width	23.5750
Bottom Sash Height	38.0000
Top Glass Height	25.625
Bottom Glass Width	21.6875
Bottom Glass Height	28.6250
Screen Width	21.3750
Screen Height	54.8125
Top Sash Weight (plus 3 lb)	30 lb
Top Balance Size (C.F.)	59R2
Top Balance Size (Sprint)	22.7R
Bottom Sash Weight	48 lb
Bottom Balance Size (C.F.)	81G
Bottom Balance Size (Sprint)	47.5R
Glass Opening Height	21.2190
Glass Opening Width	23.0825
Excess Opening Height	3.2510

Exact Size

Width:	25.625
Height:	57.675

Elevation: Sidel Elevation
 Opening: Exact Size
 Type: Standard
 Screen: Full
 Glass: Double Strength (3 mm)

At Sash Center

* $21.9 \times 54.8 = 1200.1 \div 144 = 8.34 \text{ sq. ft}$