

CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 10/25/10

APPEAL PROPERTY ADDRESS: 312 BURGESS #1

APPLICANT NAME: Saint Paul & Ramsey PHONE NUMBER: 266-1143
ON BEHALF OF JUSTIN BOWSER (owner)

PERMIT NUMBER: _____

TYPE OF WINDOW: DOUBLE HUNG

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 9.15 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 19" DIFFERENCE FROM REQUIRED OPENING: 1"

HEIGHT OF OPENING: 28" DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING
OF FINISHED FLOOR: 248" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____


Select a Model:

(Model 0201)	
Excaltbur Double Hung	
Top Sash Width	20.2500
Bottom Sash Width	21.2500
Top Glass Width	18.4235
Bottom Glass Width	19.5625
Top Glass Height	31.6000
Bottom Glass Height	34.1875
Screen Width	19.8125
Screen Height	66.6250
Top Sash Weight (plus s/lb)	22 lb
Top Balance Size (CF)	58 Bl
Top Balance Size (Squall)	28.88
Bottom Sash Weight	19 lb
Bottom Balance Size (CF)	58 Bl
Bottom Balance Size (Squall)	19.0840
Gross Opening Height	38.6000
Gross Opening Area (sq.ft)	3.7130

Width:	23.5	Equal Size	23.5
Height:	69.5		69.5
Estimator:	Sokol Brandon	Opening:	Equal Size
Type:	Shrinked	Screen:	Full
Glass:	Double Strength (3mm)		

W. Sash Calculator

* $19.8 \times 66.6 = 1318.6 \div 144 = 9.15 \text{ sq ft}$



Saint Paul - Ramsey County Department of Public Health
 Environmental Health Section
 2785 White Bear Avenue North Suite 350
 Maplewood, MN 55109-1320
 FAX: (651) 266-1177

Date: _____

FACSIMILE TRANSMISSION
 Cover Sheet and Transmittal Form

To FAX#: 6-8574

RECEIVED
 OCT 25 2010
 CITY CLERK

To: Mai Yang, Paralegal
 Location: Legislative Hearing Office
City of St. Paul
 Sender: Bruce Noyes / Jim Hannarelli
St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 DANIEL

Message:

Request for Egress Window Non-Compliance Determination
Attachments: Egress Window Non-Compliance Determination Form
: WINDOW SPECS
312 BURGESS #1

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.