



APPLICATION FOR APPEAL

RECEIVED

NOV 28 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In

YOUR HEARING Date and Time:

Tuesday, 12-13-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 878-880 Dayton Ave City: ST. PAUL State: MIN Zip 55104

Appellant/Applicant: ALVIN HENRIE Email MICSIRLO@COMCAST.NET

Phone Numbers: Business _____ Residence 651 927 4689 Cell _____

Signature: Alvin J Henrie Date: 28 Nov 2011

Name of Owner (if other than Appellant): TRUST: MAVIS HENRIE

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☒ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☒ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other _____

Failure TO MAINTAIN WHAT?

SMOKE DETECTOR STATUS?



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

November 18, 2011

ALVIN HENKE
MAVIS HENKE
871 DAYTON AVE
ST PAUL MN 55104-6542

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES
878 DAYTON AVE

Ref. # 107661

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on November 17, 2011. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. **A reinspection will be made on or after December 15, 2011. All work must be approved under permit by this time.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. Basement - Dryer - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989. - Provide inspection and approval under permit.
2. Basement - MFGC 304 - Provide approved combustion make up air in compliance with the mechanical code. This work may require a permit(s). Call DSI at (651) 266-9090. - Provide inspection and approval under permit.
3. Exterior - SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint. - Provide inspection and approval under building permit.

4. Lower Unit - SPLC 34.11, SBC 2902.1, SPLC 34.17, MPC 4715.0200.C - Provide an approved number and type of plumbing fixtures.-Provide and maintain an approved private hand sink. This work may require a permit(s). Call DSI at (651) 266-8989. Provide and maintain an approved kitchen sink. Provide inspection and approval under permit.
Provide and maintain an approved private tub or shower. Provide inspection and approval under permit.
5. Upper Unit - MN Stat. 299F.362 - Immediately provide and maintain a smoke detector located outside each sleeping area. - Provide smoke detector in approved location outside of bedroom in addition to other detectors inside of bedrooms.
6. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at mitchell.imbertson@ci.stpaul.mn.us or call me at 651-266-8986 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Mitchell Imbertson
Fire Inspection
Ref. # 107661