



APPLICATION FOR APPEAL

RECEIVED
APR 06 2012
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, April 17, 2012

Time 1:30 p.m.

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 826 Portland City: St. Paul State: MA Zip: 55105

Appellant/Applicant: LORI Kustritz Email lorikustritz@Mac.com

Phone Numbers: Business 6512839370 Residence _____ Cell _____

Signature: [Handwritten Signature] Date: _____

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): 80 Virginia street 55102

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other _____

Should not be on Rental Registration Program

This is an owner occupied property.

Note: Inspector is okay with this late appeal.

-ccn 4-6-12
Revised 4/22/2011



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

March 14, 2012

EMK HOLDING CO
80 VIRGINIA ST
ST PAUL MN 55102-2114

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES
826 PORTLAND AVE

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on March 13, 2012. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately.

A reinspection will be made on April 6, 2012 at 1:00 PM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. SPLC 34.19 - Provide access to the inspector to all areas of the building.
2. Double hung window - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)-266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-
Second floor bedroom
11.75 h x 23 w Glazed 3.7 sq ft
3. Exterior - SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.

4. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
5. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector