



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

April 13, 2012

Charles Nosie  
12200 Upper Heather Ave North  
Hugo MN 55038

VIA EMAIL: [chuck@cnosieconstruction.com](mailto:chuck@cnosieconstruction.com)

Re: Appeal for property at 1078 Fifth Street East

Dear Mr. Nosie:

This is to confirm that Marcia Moermond, Legislative Hearing Officer further reviewed your appeal in the above-referenced matter and recommended that the City Council deny the appeal on the venting of the sinks described in Item 7 of the orders. Per the senior trade inspector, "wet venting" is not a legal or safe approach to vent the sinks in question. The venting clearly was updated following construction; therefore, this part of the plumbing code would apply. Also, this venting is a life safety issue as sewer gases could enter and accumulate in the residence.

The City Council Public Hearing is scheduled for Wednesday, April 18, 2012 at 5:30 p.m. in Room 300 Council Chambers if you wish to contest further.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

MV

Mai Vang  
Legislative Hearing Coordinator

c: Fire Supervisors (email)  
Wayne Spiering (email)