



APPLICATION FOR APPEAL

RECEIVED

NOV 01 2010

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Nov. 9

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 861 Parkview Ave City: St. Paul State: MN Zip: 55117

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: 10-26-10

Name of Owner (if other than Appellant): Ching and Marie Wang

Address (if not Appellant's): 861 Parkview Ave

Phone Numbers: Business _____ Residence 651-489-5480 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

WE are appealing 1 bedroom double hung window that will not comply w/ Egress Policy. The current dimensions will be 1 1/4" short in operable height but will exceed operable width by 4". The homeowners would like to keep the existing style. Please Approve.

Revised 8/20/2010



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 26, 2010

APPEAL PROPERTY ADDRESS: 861 PARKVIEW AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 914574
TYPE OF WINDOW: Double Hung
NUMBER OF WINDOWS: 1

Total Glazed Area	10.2 sq. ft.	Difference from Required Area	+ 5.2 sq. ft.
Width of Opening	24"	Difference from Required Opening	+ 4"
Height of Opening	22 3/4"	Difference from Required Opening	- 1 1/4"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.