



APPLICATION FOR APPEAL

RECEIVED

FEB 07 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 2-15-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

WATKIN

Address Being Appealed:

Number & Street: 650 S Pt. Douglas Rd City: ST. PAUL State: MD Zip: 55119

Appellant/Applicant: DAVID HULBERT Email _____

Phone Numbers: Business _____ Residence 651-459-5704 Cell 651-673-9051

Signature: David Hulbert Date: 2-17-11

Name of Owner (if other than Appellant): SAME

Address (if not Appellant's): 1132 McCANNON AVE. - ST. PAUL PARK, MN

Phone Numbers: Business _____ Residence 651-459-5704 Cell 651-673-9051

55071

What Is Being appealed and why?

Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: January 7, 2011

D. NELSON 651-266-9027

APPEAL PROPERTY ADDRESS: 650 POINT DOUGLAS ROAD S

APPLICANT NAME: K DESIGNERS

PHONE NUMBER: 651-266-9027

PERMIT NUMBER: 10 930016

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS Three

Total Glazed Area Minimum 5 Square Feet	11.7 sq. ft.	Difference from Required Area	+6.0 sq. ft.
Width of Opening Minimum 20 Inches	38"	Difference from Required Opening	+18"
Height of Opening Minimum 24 Inches	17"	Difference from Required Opening	-7"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	

COMMENTS:

*CALL 617 30 70
0900 AM*

Reviewed by: David Nelson