



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 14, 2010

APPEAL PROPERTY ADDRESS: 1865 PORTLAND AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 909999
TYPE OF WINDOW Casement
NUMBER OF WINDOWS 2

Total Glazed Area	6.8	Difference from Required Area	+1.8
Width of Opening	15 5/8	Difference from Required Opening	-4 3/8
Height of Opening	36 5/8	Difference from Required Opening	+12 5/8
Height of Opening to Finished Floor	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above, approval is recommended. 10-14-10 rr

Reviewed by: Rehn