



# APPLICATION FOR APPEAL

RECEIVED Saint Paul City Clerk  
FEB 01 2011 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
CITY CLERK Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

**YOUR HEARING Date and Time:**

Tuesday, 2-8-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

*mailed 2-1-11*

## Address Being Appealed:

Number & Street: 426 Mt Curve Blvd City: St. Paul State: MN Zip: 55105

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: \_\_\_\_\_

Name of Owner (if other than Appellant): Jennifer Davis-Lammers

Address (if not Appellant's): 426 Mt. Curve Blvd

Phone Numbers: Business \_\_\_\_\_ Residence 651-670-3518 Cell \_\_\_\_\_

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

*We are appealing 1 replacement window that will not comply w/ Egress Policy. Current window has DB operating style, the homeowner would like to change operating style to casement. Operable width will be short by 3", operable height exceeded substantially. Please Approve.*



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: January 25, 2011

APPEAL PROPERTY ADDRESS: 426 MOUNT CURVE BLVD  
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION  
PHONE NUMBER: 651-266-9071  
PERMIT NUMBER: 11 009177  
TYPE OF WINDOW: Casement  
NUMBER OF WINDOWS: 1

<b>Total Glazed Area</b> Minimum 5 Square Feet	7.5 sq.ft	<b>Difference from Required Area</b>	+ 2.5 sq.ft
<b>Width of Opening</b> Minimum 20 Inches	17"	<b>Difference from Required Opening</b>	- 3"
<b>Height of Opening</b> Minimum 24 Inches	40 1/2"	<b>Difference from Required Opening</b>	+ 20.5"
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	OK	<b>Difference from Maximum Height</b>	OK

COMMENTS: Approval to be determined by legislative hearing officer

Reviewed by: jps