

Code Enforcement Correction Notice

Vacant Building Registration

□ Other

APPLICATION FOR APPEAL

OILA OFERIK WYX 1 1 7015 BECEINED

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:	
\$25 filing fee payable to the City of Saint Paul (if cash: receipt number 905354) Copy of the City-issued orders or letter which are being appealed Attachments you may wish to include This appeal form completed Walk-In OR Mail-In	YOUR HEARING Date and Time: Tuesday, JUNE 5, 2012 Time 1:30 y.M. Location of Hearing: Room 330 City Hall/Courthouse
Address Being Appealed:	
Number & Street: 1/54 Flandrav City: 5	5 T PAU/State: Miv Zip: 55/04
Appellant/Applicant: Er	nail
Phone Numbers: Business Residence	Cell Cell
Signature:	Date: 5-11-12
Name of Owner (if other than Appellant): MARIA & Pley	
Address (if not Appellant's): 1500 mcafee	ST POUL MINU
Phone Numbers: Business Residence 774	<i>t</i> -///7 Cell
What Is Being Appealed and Why?	Attachments Are Acceptable
Vacate Order/Condemnation/ Revocation of Fire C of O Summary/Vehicle Abatement Fire C of O Deficiency List Fire C of O: Only Egress Windows	
٧ ٥	



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989 Facsimile: 651-266-8951 Web: www.stpaul.gov/dsi

May 7, 2012

RE:

ALEXANDRE HUPALO MARIA HUPALO 1508 MCAFEE ST ST PAUL MN 55106-1437

RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES 1154 FLANDRAU ST

Ref. # 114616

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on May 7, 2012. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. A reinspection will be made on June 7, 2012. THIS INSPECTION WILL NOT BE NECESSARY IF YOU HAVE PROVIDED TO THIS OFFICE THE VARIANCE GRANTED ON THE ESCAPE WINDOWS AND THE FINAL INSPECTION ON THE DRYER DUCT, AND THE EXISTING FUEL BURNING SAFETY TEST.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

- All Bedrooms MSFC1026.1 Provide and maintain an approved escape window from 1. each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Double hung windows. 20inches openable height. Openable width is 31 inches. Sill 27 inches. Glazed is 48 inches in height by 28 inches in width.
- 2. SPLC 34:11 (6), 34:34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

3. UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work will require a permit(s). Call DSI at (651) 266-8989.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas Fire Inspector Ref. # 114616