



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

NOV 01 2010

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Nov. 9

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1655 Blair Ave City: St. Paul State: MN Zip: 55104

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Kathy & Frank Schweigert

Address (if not Appellant's): 1655 Blair Ave

Phone Numbers: Business _____ Residence 651-645-4953 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 7 replacement windows that will not comply w/ Egress policies. Current dimensions will be 1" short in operable height and will exceed minimum requirements in operable width and overall glazed area. Homeowner wants to keep style consistent. Please approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 28, 2010

APPEAL PROPERTY ADDRESS: 1655 BLAIR AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 915611
TYPE OF WINDOW: Double Hung
NUMBER OF WINDOWS 7

Total Glazed Area	11 <i>sqft</i>	Difference from Required Area	+6 <i>sqft</i>
Width of Opening	26 3/8"	Difference from Required Opening	+6 3/8"
Height of Opening	23"	Difference from Required Opening	-1"
Height of Opening to Finished Floor	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above approval is recommended. 10-29-10 rr

Reviewed by: Rehn