



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

November 10, 2010

Laura Kueny  
Pella Windows  
obo Hlee Lee  
1868 Beam Avenue  
Maplewood, MN 55109

Re: Appeal for property at 1856 Orange Avenue East  
File ID: ALH 10-328

Dear Ms. Kueny:

This is to confirm that on November 5, 2010, Marcia Moermond, Legislative Hearing Officer reviewed your appeal in the above-referenced matter and recommended granting a 3-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 21 inches high by 23 inches wide.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang  
Hearing Coordinator

cc: Fire Supervisors  
Jim Bloom  
Ryan Rehn  
Stephen Ubl

