



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

June 22, 2011

Ester Dahl  
Window World  
2211 – 11<sup>th</sup> Ave E, Ste. 130  
North St. Paul, MN 55109

VIA EMAIL: [esterd@windowworldmn.com](mailto:esterd@windowworldmn.com)

Re: Appeal for property at 1311 Clarence Street  
File ID: RLH WP 11-29

Dear Ms. Dahl:

This is to confirm that on June 10, 2011, Marcia Moermond, Legislative Hearing Officer reviewed the above-referenced appeal and stated that although the windows met the egress window requirement, steps must be installed full width below the egress windows to address the sill height issue.

Please note that this matter is before the City Council on Wednesday, July 6, 2011 at 5:30 p.m. in Room 300 Council Chambers.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

/s/  
Mai Vang  
Legislative Hearing Coordinator

cc: Fire Supervisors (email)  
Pat Fish (email)  
Jim Bloom (email)  
Dave Nelson (email)  
Stephen Ubl (email)  
File

