

RECEIVED

OCT 25 2010

CITY CLERK

# APPLICATION FOR APPEAL



Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

**YOUR HEARING Date and Time:**

Tuesday, NOV. 2

Time 1:30

Location of Hearing:  
Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1248 Como Blvd E City: St. Paul State: MN Zip: 55117

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: \_\_\_\_\_

Name of Owner (if other than Appellant): Ted Benson

Address (if not Appellant's): 1248 Como Blvd E

Phone Numbers: Business \_\_\_\_\_ Residence 651-488-7271 Cell \_\_\_\_\_

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 3 bedroom windows that will not comply w/ Egress policy. Current dimensions will be short in operable height by 1 1/8". Operable width and overall glazed area will be exceeded. Please Approve.



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: October 21, 2010

APPEAL PROPERTY ADDRESS: 1248 COMO BLVD E  
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION  
PHONE NUMBER: 651-266-9071  
PERMIT NUMBER: 10 913117  
TYPE OF WINDOW: Double Hung  
NUMBER OF WINDOWS: 3

<b>Total Glazed Area</b>	10.3 sq. ft.	<b>Difference from Required Area</b>	+ 5.3 sq. ft.
<b>Width of Opening</b>	24"	<b>Difference from Required Opening</b>	+ 4"
<b>Height of Opening</b>	22 7/8"	<b>Difference from Required Opening</b>	- 1 1/8"
<b>Height of Opening to Finished Floor</b>	NA	<b>Difference from Maximum Height</b>	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B. H.