

The City Clerk needs the following to process your appeal:

APPLICATION FOR APPEAL

RECEIVED

JUL 07 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

\$25 filing fee payable to the City of (if cash: receipt number) Copy of the City-issued orders or le are being appealed Attachments you may wish to include This appeal form completed Walk-In OR Mail-In	tter which	YOUR HEARING Date and Time: Tuesday, 7-26-1/ Time / 30 Location of Hearing: Room 330 City Hall/Courthouse
Address Being Appealed:		
Number & Street: 1827 Orange Alecity: SAWT State: PAW zip: 55119		
Appellant/Applicant: Choua Kong Email hyhena 98 & Yahoo. Con,		
Phone Numbers: Business Residence Cell 651-283-8893		
Signature:		
Name of Owner (if other than Appellant):		
Address (if not Appellant's):		
Phone Numbers: Business	Residence	Cell
What Is Being Appealed and Why? Attachments Are Acceptable		
Vacate Order/Condemnation/ Revocation of Fire C of O		
□ Summary/Vehicle Abatement		
▼ Fire C of O Deficiency List	AHK-5PLC 34.13	, MSF (1026, / -A+tic
□ Fire C of O: Only Egress Windows		
$\ \ \Box \ \ \textbf{Code Enforcement Correction Notice}$		
□ Vacant Building Registration		
□ Other		
		D



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806

 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi

June 17, 2011

CHOUA KONG BLIA LEE 2073 5TH ST E ST PAUL MN 55119

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES

1827 ORANGE AVE E

Ref. # 109883

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on June 17, 2011. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. A reinspection will be made on July 18, 2011 at 2:00 P.M..

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

- 1. Attic SPLC 34.13 (1) Provide and maintain all habitable areas with a ceiling height of 7 feet over 1/2 the floor area.-Ceiling center = 3 feet in width of the ceiling is 6 feet high. The ceiling on the north and south side is 5 feet 3 inches in height..
- 2. Attic MSFC1026.1 Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)-266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Measured 14inches openable height and 27inches in width. Sill is 31inches. Glazed is 28inches in height by 24inches in width.
- 3. MN Stat. 299F.362 Immediately provide and maintain a smoke detector located outside each sleeping area.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas Fire Inspector Ref. # 109883