

**From:** Vasquez, Terri (CI-StPaul)  
**To:** Lallier, Rich (CI-StPaul); Kuebler, David (CI-StPaul); St Martin, Paul (CI-StPaul); Gillen, Brent (CI-StPaul)  
**Subject:** Denial letter for 1776 Yorkshire Ave.  
**Date:** Friday, August 30, 2013 11:44:30 AM  
**Attachments:** SCN\_20130830113433\_001.pdf  
Yorkshire.pdf

---

Attached is the letter of denial for the encroachment permit request for a dump pump drain pipe to drain under the sidewalk and onto the boulevard in front of 1776 Yorkshire Ave.

I've also attached the original request and plan for your information.

If you have any questions, please feel free to call me.

- Terri



City of Saint Paul  
Christopher B. Coleman, Mayor

Technical Services Division  
1000 City Hall Annex  
25 W 4<sup>th</sup> Street  
Saint Paul, MN 55102-1660

Phone: (651) 266-8850  
Fax: (651) 266-8855

August 30, 2013

Mr. Gennady Lyubeznik  
1776 Yorkshire Avenue  
Saint Paul, Minnesota 55116-2459

Subject: **Encroachment Permit Application for 1776 Yorkshire Avenue**

Dear Mr. Lyubeznik:

The City of St. Paul Department of Public Works has received and reviewed your application for an encroachment permit to place a drain under the sidewalk and onto the boulevard in front of your property at 1776 Yorkshire Avenue. After review by various City Departments and Utility Companies, your request for an encroachment permit, as described in your application, is denied.

The Department of Public Works offers the following reasons for denying your encroachment permit request:

- 1) Allowing direct discharge to the curb or boulevard is not a Standard Best Practice in the City.
- 2) As per Chapter 134 of the St. Paul Legislative Code, your request can be reasonably accomplished on your private property.

If you wish to appeal this decision you may contact the Director of Public Works, Rich Lallier, at (651) 266-6099. His address is 25 4<sup>th</sup> Street West, 1500 City Hall Annex, St. Paul, MN 55102.

If you have any additional questions regarding the encroachment permit process, please call me at (651) 266-6217.

Sincerely,

David Kuebler, P.E.  
ROW Management Section  
Traffic and Lighting Division  
St. Paul Public Works Department

cc: Rich Lallier  
Paul St. Martin  
Brent Gillen

**From:** Nelson, Kevin (CI-StPaul)  
**To:** Vasquez, Terri (CI-StPaul); Sima, Anca (CI-StPaul); Brimer, Scott (CI-StPaul); Paavola, Colleen (CI-StPaul); Kuehler, David (CI-StPaul); St Martin, Paul (CI-StPaul); Czala, Al (CI-StPaul); Jorgensen, Zach (CI-StPaul); Chaple, Graeme (CI-StPaul); scott\_ruppert@cable.comcast.com; bill.gacke@centurylink.com; bernard.e.gille@xcelenergy.com; john.e.browsers@xcelenergy.com; Ung, Henry (CI-StPaul); Stein, Don (CI-StPaul)  
**Subject:** RE: Encroachment permit request  
**Date:** Friday, August 02, 2013 9:28:48 AM

---

This is inappropriate. Direct discharge to the curb or boulevard should never be allowed.

Kevin L Nelson, PE  
Street Maintenance Manager  
St. Paul Public Works Dept.  
873 N. Dale Street  
St. Paul, MN 55103  
651-266-9714

-----Original Message-----

**From:** Vasquez, Terri (CI-StPaul)  
**Sent:** Friday, August 02, 2013 9:11 AM  
**To:** Sima, Anca (CI-StPaul); Brimer, Scott (CI-StPaul); Paavola, Colleen (CI-StPaul); Kuebler, David (CI-StPaul); St Martin, Paul (CI-StPaul); Nelson, Kevin (CI-StPaul); Czala, Al (CI-StPaul); Jorgensen, Zach (CI-StPaul); Chaple, Graeme (CI-StPaul); scott\_ruppert@cable.comcast.com; bill.gacke@centurylink.com; bernard.e.gille@xcelenergy.com; john.e.browsers@xcelenergy.com; Ung, Henry (CI-StPaul); Stein, Don (CI-StPaul)  
**Subject:** Encroachment permit request

for drainage pipe under sidealk in front of 1776 Yorkshire Ave.