



APPLICATION FOR APPEAL

RECEIVED
JUN 27 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, July 12 2011
Time 1:30 pm
Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1491 Kent St. City: St. Paul State: MN Zip: 55117

Appellant/Applicant: Craft Masters Remodeling Email: turnmac@gmail.com

Phone Numbers: Business 651-757-4100 Residence _____ Cell 651-278-2708

Signature: [Signature] Date: 6/22/11

Name of Owner (if other than Appellant): Jan Mehlhoff

Address (if not Appellant's): 1491 Kent St., St. Paul MN. 55117

Phone Numbers: Business _____ Residence _____ Cell 651-356-5915

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

1 window on office.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

RECEIVED
JUN 27 2011
CITY CLERK

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 6/22/11

APPEAL PROPERTY ADDRESS: 1491 KENT ST

APPLICANT NAME: CRAFT MASTERS REMOD. PHONE NUMBER: 651 757-4100

PERMIT NUMBER: 2011144289

TYPE OF WINDOW: Double hung

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 27 7/8 x 44 1/2 $\approx 8.7 \text{ sq FT}$ DIFFERENCE FROM REQUIRED AREA: + 3 sq FT

WIDTH OF OPENING: 24" DIFFERENCE FROM REQUIRED OPENING: + 4"

HEIGHT OF OPENING: 16 1/2" DIFFERENCE FROM REQUIRED OPENING: - 7 1/2"

HEIGHT OF OPENING TO FINISHED FLOOR: 36" DIFFERENCE FROM MAXIMUM HEIGHT: + 8"

RECOMMENDATION (IF APPLICABLE): _____

FROM: Virgil Thomas

JAN. L. MEHLHOFF


1491 KENT STREET
SAINT PAUL, MN 55117
651-356-5915

RECEIVED
JUN 21 2011
CITY CLERK

To Whom It May Concern:

I have lived at 1491 Kent Street since August 2009. The room in question (middle of the house on the north side) has never been used as a bedroom. It is an office. Please contact me if you have any questions.

Thank you.



Jan. L. Mehlhoff
