



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

January 26, 2011

Daniel Schmidt
RC Public Health
2785 White Bear Ave N, Ste. 350
Maplewood, MN 55109

VIA EMAIL: Daniel.schmidt@co.ramsey.mn.us

Re: Appeal for property at 554 Winslow Avenue
File ID: ALH 11-130

Dear Mr. Schmdit:

This is to confirm that on January 21, 2011, Marcia Moermond, Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 4-inch variance on the openable height of three double hung replacement egress bedroom windows which measured at 20 inches high by 23 inches wide.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Stephen Ubl (email)
File

