



# APPLICATION FOR APPEAL

RECEIVED

NOV 23 2010

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 12/7/10

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 2010 Bush Ave City: St. Paul State: MN Zip: 55119

Appellant/Applicant: Corey Lindell Email: corey.lindell@gmail.com

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell 952-210-7588

Signature: Corey Lindell Date: 11-22-2010

Name of Owner (if other than Appellant): same as above

Address (if not Appellant's): 15071 Summerhill Drive, Eden Prairie, MN 55346

Phone Numbers: Business \_\_\_\_\_ Residence 952-937-9614 Cell 952-210-7588 (preferred)

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows Item #7
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Windows were/are part of the original existing house structure. They are double-hung and have an opening of 28" wide x 20" high. They would meet egress if rotated on their side. There is more than enough room for someone to escape if needed.



CITY OF SAINT PAUL  
*Christopher B. Coleman, Mayor*

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

November 19, 2010

CORY LINDELL  
15071 SUMMERHILL DR  
EDEN PRAIRIE MN 55346-2618

### FIRE INSPECTION CORRECTION NOTICE

RE: 2010 BUSH AVE  
Ref. #112927  
Residential Class: C

Dear Property Representative:

Your building was inspected on November 19, 2010 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

**A re-inspection will be made on January 6, 2011 at 12:30pm.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

**YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.**

#### DEFICIENCY LIST

1. Basement - Dryer Vent - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work requires a permit. Call DSI at (651) 266-8989.- Remove the unapproved flexible plastic exhaust duct and replace with the approved type. All work must be done under permit.