



APPLICATION FOR APPEAL

RECEIVED Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
NOV 24 2010 Saint Paul, Minnesota 55102
CITY CLERK Telephone: (651) 266-8560

NOV 24 2010
CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Dec. 14, 2010

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 704 IOWA Ave. E. City: ST. PAUL State: MN Zip: 55106

Appellant/Applicant: Custom Remodders Inc Dan Parker Email: Judy.h@customremoddersinc.com

Phone Numbers: Business (651) 784-2646 Residence (651) 278-8416 Cell _____

Signature: David Dube Date: 11/24/2010

Name of Owner (if other than Appellant): Zongqun / MATINA Xi'ong

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Permit # 2010310634

Attn: Dan



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 18, 2010

APPEAL PROPERTY ADDRESS: 704 IOWA AVE E

APPLICANT NAME: CUSTOM REMODELERS INC

PHONE NUMBER: 651-266-9020

PERMIT NUMBER: 10 310634

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 3 bedrooms

Total Glazed Area	6.4 sq. ft.	Difference from Required Area	+1.4 sq. ft ok
Width of Opening	31"	Difference from Required Opening	+11" ok
Height of Opening	13"	Difference from Required Opening	-11"
Height of Opening to Finished Floor	45"	Difference from Maximum Height	+3' ok

COMMENTS:

Reviewed by: David Tank