

□ Summary/Vehicle Abatement

Fire C of O: Only Egress Windows

Vacant Building Registration

OtherOtherOther

Code Enforcement Correction Notice

□ Fire C of O Deficiency List

APPLICATION FOR APPEAL

MAR 22 2011 CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:	YOUR HEARING Date and Time:
\$25 filing fee payable to the City of Saint Paul	1/ 1
(if cash: receipt number)	Tuesday, 4-5-//
_/ Copy of the City-issued orders or letter which	1126
are being appealed	Time
 Attachments you may wish to include 	Location of Hearing:
This appeal form completed	Room 330 City Hall/Courthouse
	walk-in
Address Being Appealed:	
Number & Street: 779 6TH ST & City: ST PAUL State: MN Zip:	
Appellant/Applicant: BELL PERSON Email bpers @live.co	
Phone Numbers: Business 6/2889 4449 Residence 9524709370Cell	
Signature: Um Franco Date: 3/22/2011	
Name of Owner (if other than Appellant): TANGET BEAR BETATE	
Address (if not Appellant's): 15 BROADWAY SUTTE 660 FAR60	
Phone Numbers: Business THOMAS (Residence) 01-361-76100 NO 5810	
What Is Being appealed and why? Attachments Are Acceptable	
Vacate Order/Condemnation/ Revocation of Fire C of O	



CITY OF SAINT PAUL

Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-8989 Saint Paul, MN 55101-1806

Fax: 651-266-8951

March 16, 2011

BILL PERSSON 20115 EXCELSIOR BLVD SHOREWOOD MN 55331

CORRECTION NOTICE - COMPLAINT INSPECTION

 779.6^{TH} ST E RE:

Ref. # 108028

Dear Property Representative:

An inspection was made of your building on March 16, 2011 in response to a referral. You are hereby notified that the following deficiency list must be corrected immediately.

A reinspection will be made on or after April 18, 2011.

Failure to comply may result in a criminal citation or revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. INTERIOR - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupanices handout for more information.-Upon inspection, double-hung window in west bedroom measured 20.5 inches openable height x 36.5 inches openable width.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd,

Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: kelly booker a ci stpaul mn us or call me at 651-266-8985 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Kelly Booker Fire Inspector