



Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

RECEIVED
JAN 18 2011
Date: _____
CITY CLERK

COVER SHEET AND TRANSMITTAL FORM
FACSIMILE TRANSMISSION

To FAX#: 6-8574

| | |
|-----------|---|
| To: | <u>Mai Yang Paralegal</u> |
| Location: | <u>Legislative Hearing Office</u> <u>City of St Paul</u> |
| Sender: | <u>Daniel Schmidt / Jim Hannareilly</u> <u>St. Paul - Ramsey Cty. Dept. of Public Health</u> |

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1173 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination
Attachments: Egress Window Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 1-18-11

APPEAL PROPERTY ADDRESS: 711 VAN BUREN

APPLICANT NAME: PUBLIC HEALTH - DANIEL
OW BENEF OF KYLE MURPHY 651-261-9599 PHONE NUMBER: 651-266-1143

PERMIT NUMBER:

TYPE OF WINDOW: DOUBLE-HUNG

NUMBER OF WINDOWS: 2 for 2 Bedrooms

TOTAL GLAZED AREA: 7.02 sqft

DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 24"

DIFFERENCE FROM REQUIRED OPENING: COMPLIES

EIGHT OF OPENING: 23.375"

DIFFERENCE FROM REQUIRED OPENING: 625" OR 5"

EIGHT OF FINISHED FLOOR: 448"

DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE):

FROM: _____