



APPLICATION FOR APPEAL

RECEIVED

MAY 31 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 6-14-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

e-mail

Address Being Appealed:

Number & Street: 2221 Edgumbe Rd City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: 05/26/11

Name of Owner (if other than Appellant): Annette & Kirby Hanson

Address (if not Appellant's): 1920 W City Rd C Roseville MN 55113

Phone Numbers: Business 651-264-4088 Residence 651-699-2231 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 3 replacement windows that will not comply w/ Egress policy. Opening width will be 17" and operable height will be exceeded by 10". These windows are less than 3' from sill to grade. Please Approve. Email hearing information. DO NOT MAIL. Thanks!

Revised 8/20/2010



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: May 26, 2011

APPEAL PROPERTY ADDRESS: 2221 EDGCUMBE ROAD
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-264-4914
PERMIT NUMBER: 11 147209
TYPE OF WINDOW: Casement
NUMBER OF WINDOWS: 3

Total Glazed Area Minimum 5 Square Feet	6.5	Difference from Required Area	+1.5
Width of Opening Minimum 20 Inches	17	Difference from Required Opening	-3
Height of Opening Minimum 24 Inches	34 ¼	Difference from Required Opening	+10 ¼
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	ok

COMMENTS: With the information provided approval is recommended. 5-26-11 rr

Reviewed by: Rehn