

RECEIVED

OCT 13 2010

CITY CLERK

2010  
CITY CLERK



# APPLICATION FOR APPEAL

Saint Paul City Clerk  
15 W. Kellogg Blvd., 310 City Hall  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8688

1. Address of Property being Appealed: <u>794 Pascal St N</u>	2. Number of Dwelling Units: <u>SFD</u>	3. Date of Letter Appealed: <u>10-11-10</u>
--	--	--

4. Name of Owner: Patty Stotheim  
 Address: 794 Pascal Street City: St. Paul State: MN Zip: 55104  
 Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cellular \_\_\_\_\_  
 Signature: \_\_\_\_\_

5. Appellant / Applicant (if other than owner): Renewal by Andersen  
 Address: 1920 W Ch Rd C City: Roseville State: MN Zip: 55113  
 Phone Numbers: Business 651-264-4088 Residence \_\_\_\_\_ Cellular \_\_\_\_\_  
 Signature: Bryan Horton

6 State specifically what is being appealed and why (Use an attachment if necessary):

We are appealing the replacement of 3 bedroom double hung windows that will not comply w/ Egress Policy. The operable height will be short by 1/8", the operable width is 4" above what the minimum requires. Homeowner wants to keep the existing operating style. Please Approve.

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <u>10/14/10</u>	Fee Received: <u>25</u>	Receipt Number:	Date of Hearing: <u>Oct. 26 - 1:30</u>
-----------------------------------	----------------------------	-----------------	---

Revised 4/25/2007



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: October 12, 2010

APPEAL PROPERTY ADDRESS: 794 PASCAL ST N  
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION  
PHONE NUMBER: 651-266-9071  
PERMIT NUMBER: 10 908775  
TYPE OF WINDOW: Double Hung  
NUMBER OF WINDOWS: 3

Total Glazed Area	10.3 sq. ft.	Difference from Required Area	+ 5.3 sq. ft.
Width of Opening	24 "	Difference from Required Opening	+ 4 "
Height of Opening	22 7/8 "	Difference from Required Opening	- 1 1/8 "
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided recommend approval.

Reviewed by: B.H.