



# APPLICATION FOR APPEAL

RECEIVED

JUN 01 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR  Mail-In

YOUR HEARING Date and Time:

Tuesday, 6-12-12

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 2209/2211 GLENRIDGE City: St Paul State: MN Zip: 55

Appellant/Applicant: GREG FLY Email greg@bearexterior.com

Phone Numbers: Business 651-271-3296 Residence \_\_\_\_\_ Cell 651-271-3296

Signature: [Signature] Date: 6/1/12

Name of Owner (if other than Appellant): OAK KNOLL PROPERTIES

Address (if not Appellant's): 2000 OAK KNOLL DR

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell 651-271-3296

## What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

IT'S A DUPLEX  
2209/2211 GLENRIDGE



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: June 1, 2012

APPEAL PROPERTY ADDRESS: 2209 GLENRIDGE AVE

APPLICANT NAME: BEAR ROOFING EXTERIORS INC

PHONE NUMBER: 651-407-1987

PERMIT NUMBER: 12 040753

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS Six (3 @ each unit)

<b>Total Glazed Area</b> Minimum 5 Square Feet	11.0 sq.ft.	<b>Difference from Required Area</b>	+5.3 sq. ft.
<b>Width of Opening</b> Minimum 20 Inches	33"	<b>Difference from Required Opening</b>	+13"
<b>Height of Opening</b> Minimum 24 Inches	22"	<b>Difference from Required Opening</b>	-2"
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	OK	<b>Difference from Maximum Height</b>	

COMMENTS:

Reviewed by: David Nelson



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: June 1, 2012

2211

APPEAL PROPERTY ADDRESS: 2209 GLENRIDGE AVE

APPLICANT NAME: BEAR ROOFING EXTERIORS INC

PHONE NUMBER: 651-407-1987

PERMIT NUMBER: 12 040753

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS Six (3 @ each unit)

<b>Total Glazed Area</b> Minimum 5 Square Feet	11.0 sq.ft.	<b>Difference from Required Area</b>	+5.3 sq. ft.
<b>Width of Opening</b> Minimum 20 Inches	33"	<b>Difference from Required Opening</b>	+13"
<b>Height of Opening</b> Minimum 24 Inches	22"	<b>Difference from Required Opening</b>	-2"
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	OK	<b>Difference from Maximum Height</b>	

COMMENTS:

Reviewed by: David Nelson