


Scanned



# APPLICATION FOR APPEAL

RECEIVED  
JAN 17 2012  
CITY CLERK  
Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:	
Tuesday, <u>1-24-12</u>	
Time <u>1:30</u>	
Location of Hearing:	
Room 330 City Hall/Courthouse	

## Address Being Appealed:

Number & Street: 698 Montana Ave E City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: 01/13/12

Name of Owner (if other than Appellant): Karla Koons

Address (if not Appellant's): 698 Montana Ave E

Phone Numbers: Business \_\_\_\_\_ Residence 651-771-4054 Cell \_\_\_\_\_

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 1 double hung window that will not comply w/ Egress Policy. Sizes for the existing window are attached. The window is located at the top flight of a stairway and will be difficult to alter the opening. The homeowner would like to keep style consistent. Side Exit door located at bottom of stairs. Please Approve. All windows in home have been replaced w/ double hung operation



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

## EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: January 13, 2012

APPEAL PROPERTY ADDRESS: 698 MONTANA AVE E

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 299751

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1

<b>Total Glazed Area</b> Minimum 5 Square Feet	7.3 sq.ft.	<b>Difference from Required Area</b>	+ 2.3 sq ft.
<b>Width of Opening</b> Minimum 20 Inches	25"	<b>Difference from Required Opening</b>	+ 5"
<b>Height of Opening</b> Minimum 24 Inches	15"	<b>Difference from Required Opening</b>	- 9"
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	42"	<b>Difference from Maximum Height</b>	+ 6"

COMMENTS:

Reviewed by: Virgil E. Thomas