



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

JUN 01 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 6-14-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

mailed 6-1-11

Address Being Appealed:

Number & Street: 990 Cleveland Ave City: St Paul State: Mn Zip: 55116

Appellant/Applicant: Eric Magnuson Email: ejmagneson@cleveland.net

Phone Numbers: Business 612-483-1303 Residence same Cell same

Signature: [Signature] Date: 5/31/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): 8528 Birch Blvd, 794, Mn 5576

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
 - Summary/Vehicle Abatement
 - Fire C of O Deficiency List
 - Fire C of O: Only Egress Windows
 - Code Enforcement Correction Notice
 - Vacant Building Registration
 - Other
 - Other
 - Other
- See attached -



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

May 17, 2011

ERIC MAGNUSON
8528 BIRCH BLVD
INVER GROVE HGTS MN 55076-5137

FIRE INSPECTION CORRECTION NOTICE

RE: 990 CLEVELAND AVE S
Residential Class: B

Dear Property Representative:

Your building was inspected on May 17, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on June 17, 2011 at 10:15 AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Basement - MSFC 315.2.3 - Remove combustible storage from the fuel burning equipment rooms.
2. Basement - MSFC 1011.2 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway.-Move coat rack that is an exit obstruction at the bottom of basement steps.

3. Double hung windows - Second floor bedrooms - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.
-21.5 h x 35 w Glazed 10.4 sq ft
4. MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.
5. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.
6. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector