



CITY OF SAINT PAUL

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

June 18, 2020

Xin Zhou
19151 Broadmoore Dr
Eden Prairie MN 55346-1031

**NOTICE OF CONDEMNATION
UNFIT FOR HUMAN HABITATION
ORDER TO REMAIN VACANT**

RE: 101 COMO AVE
Ref. # 107717

Dear Property Representative:

Your building was inspected on June 17, 2020.

The building was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

A reinspection will be made on or after July 20, 2020.

CONDEMNATION OF THE BUILDING REVOKES THE CERTIFICATE OF OCCUPANCY.

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

DEFICIENCY LIST

- 1. SPLC 34.23, MSFC 110.1 - This occupancy is condemned as unfit for human habitation. This occupancy must not be used until re-inspected and approved by this office. -Building has been condemned due to extensive fire damage and utilities have been disconnected.**

2. #2 - Front entry Way & Top Floor Storage Room - MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing. -Missing cover plate to light switch by front door and top floor storage room wall by window.
3. #2 - Top Floor West Bedroom - MSFC 1030.1 - Provide and maintain an approved escape window from each sleeping room or area or discontinue use of area as a sleeping room. This work may require permit(s). Call DSI at (651) 266-8989.-Remove AC unit from window.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: Adrian.neis@ci.stpaul.mn.us or call me at 651-266-8992 between 7:30 - 9:00 a.m. Please help make Saint Paul a safer place in which to live and work.

Sincerely,

A.J. Neis
Fire Safety Inspector
Ref. # 107717

cc: Housing Resource Center
Force Unit