



APPLICATION FOR APPEAL

RECEIVED

AUG 02 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, August 9, 2011

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 603 Van Buren City: St Paul State: MN Zip: 55103

Appellant/Applicant: Wendy Teeters Email: wentoner@iaxs.net

Phone Numbers: Business _____ Residence _____ Cell 651-208-4195

Signature: [Signature] Date: 8/2/11

Name of Owner (if other than Appellant): Wendy Teeters


Address (if not Appellant's): 606 Lake St, Prescott WI 54021

Phone Numbers: Business _____ Residence _____ Cell same

What Is Being Appealed and Why?

Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other



2 side by side windows 184x23W



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

Original

July 14, 2011

WENDY TEETERS
606 LAKE ST
PRESCOTT WI 54021

FIRE INSPECTION CORRECTION NOTICE

RE: 603 VAN BUREN AVE

Dear Property Representative:

Your building was inspected on July 14, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on August 16, 2011 at 9 am.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Egress Window - SPLC 34.13 (4) - Provide and maintain a minimum egress window sill height of 48 inches. Refer to provide handout EW-1 for more information.-The bedroom window measured 18H X 23W double hung two side by side windows.
2. Exterior - SPLC 34.09 (3), 34.32 (3) - Provide or repair and maintain the window screens.
3. Exterior - SPLC 34.08 (1), 34.31 (1) - All exterior property areas shall be maintained free from any accumulation of refuse, garbage or feces.-Remove garbage from the front porch and yard.
4. Exterior - SPLC 34.09 (2), 34.32(2) - Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. This work may require a permit(s). Call DSI at (651) 266-9090.-Repair or replace the front porch decking that is damaged from moisture.

An Equal Opportunity Employer

5. Interior - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the floor in an approved manner.-Repair or replace the carpeting.
6. Interior - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the walls in an approved manner.-Patch the holes and/or cracks in the walls.
7. Interior - SPLC 34.10 (7), 34.33 (6) - Repair or replace and maintain the woodwork in an approved manner.
8. Interior - MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.
9. Interior - SPLC 34.10 (5), 34.33 (4), 34.16 - Provide and maintain interior in a clean and sanitary condition.
10. Interior - MN Stat. 299F.362 - Immediately provide and maintain a smoke detector located outside each sleeping area.
11. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
12. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: lisa.martin@ci.stpaul.mn.us or call me at 651-266-8988 between 6:30 a.m. - 8:30 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Lisa Martin
Fire Inspector