



CITY OF SAINT PAUL  
*Christopher B. Coleman, Mayor*

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

August 25, 2014

MICHELLE WEE  
2346 7TH ST W  
ST PAUL MN 55116

### **Revocation of Fire Certificate of Occupancy and Order to Vacate**

RE: 2346 7TH ST W  
Ref. # 11587

Dear Property Representative:

Your building was determined to be a registered vacant building on August 25, 2014. Since certificates are for the occupancy of buildings, it has become necessary to revoke the Certificate of Occupancy.

Saint Paul Legislative Code provides that no building shall be occupied without a Certificate of Occupancy. In order to re-occupy the building, the following deficiencies (if applicable) must be corrected and a complete Certificate of Occupancy inspection will be required.

#### DEFICIENCY LIST

1. BUILDING - ELECTRICAL/GAS SERVICE - SPLC 34.14 (2), 34.34 (5) - Provide an approved electrical/gas service adequate to meet the building's needs. This work may require a permit(s), call DSI at (651) 266-9090.-
2. BUILDING - WATER SERVICE - SPLC 34.11(4), 34.34(1) SPC 4715.0200A - Provide an adequate water supply to all water closets, sinks, showers and tubs.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: [kris.skow-fiske@ci.stpaul.mn.us](mailto:kris.skow-fiske@ci.stpaul.mn.us) or call me at 651-266-8949 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Kris Skow-Fiske  
Fire Inspector