



Saint Paul - Ramsey County Department of Public Health
 Environmental Health Section
 2785 White Bear Avenue North Suite 350
 Maplewood, MN 55109-1320
 FAX: (651) 266-1177

Date: 4-19-11 @ 1:30

FACSIMILE TRANSMISSION
 Cover Sheet and Transmittal Form

To FAX#: 6-8574

To:	<u>Mai Yang Paralegal</u>
Location:	<u>Legislative Hearing Office</u> <u>City of St. Paul</u>
Sender:	<u>Daniel Schmidt / Tim Yansarelli</u> <u>St. Paul - Ramsey Cty. Dept. of Public Health</u>

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination
Attachments: Egress Window Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 4-7-11

APPEAL PROPERTY ADDRESS: 955 FULLER
APPLICANT NAME: PUBLIC HEALTH (DANIEL) PHONE NUMBER: 651-266-1143

PERMIT NUMBER: _____
TYPE OF WINDOW: DH
NUMBER OF WINDOWS: 3

TOTAL GLAZED AREA: 7.76 sqft DIFFERENCE FROM REQUIRED AREA: COMP.
WIDTH OF OPENING: 21.3" DIFFERENCE FROM REQUIRED OPENING: COMP.
HEIGHT OF OPENING: 20.125" DIFFERENCE FROM REQUIRED OPENING: 3.875"
HEIGHT OF OPENING TO FINISHED FLOOR: 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMP.

RECOMMENDATION (IF APPLICABLE): SEE ATTACHMENT

FROM: _____

Select a Model	
(Model 0201)	Excaltibur Double Hung
Top Sash Width	22.6000
Top Sash Height	26.3125
Bottom Sash Width	21.8000
Bottom Sash Height	26.2875
Top Glass Height	21.8125
Bottom Glass Width	21.8125
Bottom Glass Height	24.6350
Screen Width	22.0025
Screen Height	40.8350
Top Sash Weight (Plus S/H)	19 lb
Top Balance Size (C-F)	ERRD
Top Balance Size (Oil)	21-TR
Bottom Sash Weight	15 lb
Bottom Balance Size (C-F)	RLG
Bottom Balance Size (Oil)	25-SR
Egress Opening Width	21.3440
Egress Opening Height	40.7250
Egress Opening Area (sq. ft.)	2.9632

*

* $22 \times 50.8 = 1117.6 \div 144 = 7.76 \text{ sq ft}$

Min. Wt: 11	Max. Wt: 52
Min. Ht: 20	Max. Ht: 34
Max. U/I: 132	

Exact Size	Width: 25.75	Height: 53.725
------------	--------------	----------------

Extinction: Select Extinction
 Opening: Exact Size
 Type: Standard
 Screen: Full
 Glass: Double Strength (3 mm)

AC Sash Calculator