



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

February 17, 2011

Kenneth & Marlys Arcand  
1964 Arlington Avenue East  
Saint Paul, MN 55119

Re: Appeal for property at 1964 Arlington Avenue East  
File ID: ALH 11-247

Dear Mr. & Mrs. Arcand:

This is to confirm that on February 8, 2011 the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 4.4-inch variance on the openable height of two double hung replacement egress bedroom windows which measured at 19.6 inches high by 27.6 inches wide.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

Mai Vang  
Legislative Hearing Coordinator

c: Fire Supervisors (email)  
Pat Fish (email)  
Jim Bloom (email)  
Stephen Ubl (email)  
File

