



APPLICATION FOR APPEAL

RECEIVED
OCT 10 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:
Tuesday, <u>10-25-11</u>
Time <u>1:30</u>
Location of Hearing:
Room 330 City Hall/Courthouse

Mailed 10-10-11

Address Being Appealed:

Number & Street: 2175 Jefferson Ave City: St Paul State: MN Zip: 55105

Appellant/Applicant: Pella Windows, Meghan Booker Email: Bookerme@pella.com

Phone Numbers: Business 612-741-9218 Residence _____ Cell _____

Signature: [Handwritten Signature] Date: 10/6/11

Name of Owner (if other than Appellant): Jennifer Conroy

Address (if not Appellant's): 2175 Jefferson Ave

Phone Numbers: Business _____ Residence 651-698-0697 Cell 651-335-0828

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

Pella is asking to replace all windows in residence with current style of Double Hung Windows.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 10/16/11

APPEAL PROPERTY ADDRESS: 2175 Jefferson Ave

APPLICANT NAME: Pella Windows PHONE NUMBER: 612-741-9218
Meghan Booker

PERMIT NUMBER: n/a - has not been applied for yet

TYPE OF WINDOW: Double Hung

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 7.4 sq. ft DIFFERENCE FROM REQUIRED AREA: +2.3 sq. ft

WIDTH OF OPENING: 22.9" DIFFERENCE FROM REQUIRED OPENING: +2.9"

HEIGHT OF OPENING: 21" DIFFERENCE FROM REQUIRED OPENING: -3"

HEIGHT OF OPENING TO FINISHED FLOOR: less than 48" DIFFERENCE FROM MAXIMUM HEIGHT: n/a

RECOMMENDATION (IF APPLICABLE): Replacing Existing double hung windows w/ new vinyl double hung windows to fit in same opening. ###

FROM: _____