

TIM'S QUALITY PLUMBING, INC.
523 Central Avenue
Osseo, MN 55369
763-424-3258

RPZ TEST RESULT FORM

DATE TESTED 11/1/12

ADDRESS 1660 Cumberland Street
Saint Paul, MN 55117

RPZ SERIAL NUMBER 1096921

MODEL Wilkins 975

SIZE 1/2"

#1 CHECK VALVE CLOSED TIGHT-OK

#1 CHECK VALVE PSI DIFF 6.3

#2 CHECK VALVE CLOSED TIGHT-OK

RELIEF PRESSURE DIFF 3.2

TESTER ID 067257-BT

TESTER SIGNATURE on file

TESTER NAME (PRINT) Daniel T. Wagner

Tim's Quality Plumbing

A Aart's Quality Plumbing
 Accounting Office (763-424-3258)
 523 Central Avenue
 Osseo, MN 55369

Invoice

Date	Invoice #
12/21/2012	206820

Bill To
PRC HOMES 1043 GRAND AVE #309 ST. PAUL, MN 55105 ATTN: PEGGY CHUN

*Left msg
4/15 3PM*

P.O. No.	Terms	Project

Quantity	Description	Rate	Amount
	REPLACED TEMP & PRESSURE GAUGE ON BOILER THAT WAS BROKEN. ALSO, REPLACED PRESSURE RELIEF VALVE THAT WAS LEAKING. CHECKED OPERATION AND PERFORMED ORSAT TEST ON THE BOILER.	620.00	620.00
	DEDUCT \$185 FOR ORSAT TEST ON BOILER & \$40 FOR PERMIT none	-225.00 0.00%	-225.00 0.00

*Emailed
Invoices
5/14*

If there is ever any problem with any of our work, please report it immediately. Thank you.		Total	\$395.00
---	--	--------------	----------

Tim's Quality Plumbing

A Aart's Quality Plumbing
 Accounting Office (763-424-3258)
 523 Central Avenue
 Osseo, MN 55369

Invoice

Date	Invoice #
11/1/2012	206244

11/9

Left msg

4/15

3pm

Bill To
PRC HOMES 1043 GRAND AVE #309 ST. PAUL, MN 55105 ATTN: PEGGY CHUN

P.O. No.	Terms	Project

Quantity	Description	Rate	Amount
	RPZ TEST DONE AT 1660 CUMBERLAND STREET ST PAUL, MN 55105 none	230.00 0.00%	230.00 0.00
<p>Mailed 11/7/12</p> <p>Emailed Invoices 5/14</p>			
If there is ever any problem with any of our work, please report it immediately. Thank you.		Total	\$230.00