



APPLICATION FOR APPEAL

RECEIVED

MAR 02 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number 9051304)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:
 Tuesday, March 13, 2012
 Time 1:30 p.m.
 Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: ~~1323~~ 1391 Stanford City: St Paul State: MN Zip: 55105

Appellant/Applicant: Jason Koenig Email: jason@theoddcoupleteam.com

Phone Numbers: Business 612-600-4514 Residence _____ Cell 612-600-4514

Signature: _____ Date: 3/2/2012

Name of Owner (if other than Appellant): SAME

Address (if not Appellant's): SAME

Phone Numbers: Business SAME Residence SAME Cell SAME

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
 - Summary/Vehicle Abatement
 - Fire C of O Deficiency List
 - Fire C of O: Only Egress Windows
 - Code Enforcement Correction Notice
 - Vacant Building Registration
 - Other
1. Back Stairway - Like to completely replace. Will pull permit to do, however like extension for better weather
- 4% escape window too small. would like exception to maintain integrity of home.
5. extension due to weather.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

February 22, 2012

JASON D KOENIG
1823 JULIET AVE
ST PAUL MN 55105-1701

RECEIVED

MAR 02 2012

CITY CLERK

FIRE INSPECTION CORRECTION NOTICE

RE: 1391 STANFORD AVE
Residential Class: C

Dear Property Representative:

Your building was inspected on February 17, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on March 23, 2012 at 10:30 AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Back stairway - Upper unit - SPLC 34.09 (2), 34.32(2) - Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. This work requires a permit(s). Call DSI at (651) 266-9090.
2. Back steps - Lower unit - SPLC 34.09 (2) 34.32 (2) - Provide an approved handrail. The top of the handrail must be between 34 and 38 inches above the treads and run the entire length of the stair.
3. Bathroom mirror - Lower level - SPLC 34.12 (2), 34.35 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition.

4. Double hung - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-
Lower unit
17.5 h x 26.5 w Glazed 6.4 sq ft
5. Garage - SPLC 34.08 (5), 34.31 (3) - Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Scrape and remove chipped and peeling paint. Repaint in a professional manner.
6. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
7. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.
8. UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector

Reference Number 114512