



Saint Paul - Ramsey County Department of Public Health  
Environmental Health Section  
2785 White Bear Avenue North Suite 350  
Maplewood, MN 55109-1320  
FAX: (651) 266-1177

COVER SHEET AND TRANSMITTAL FORM  
FACSIMILE TRANSMISSION

Date: 3-15-11

TO FAX#: 6-8574

RECEIVED  
FEB 28 2011  
CITY CLERK

To: Mai Yang Paralegal

Location: Legislative Hearing Office  
City of St Paul

Sender: Daniel Schmidt / Jim Vannorelly  
St. Paul-Ramsey Cty. Dept. of Public Health

This transmission consists of \_\_\_\_\_ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1173 (DANIEL SCHMIDT)

Request for Egress Windos Non-Compliance Determination  
Attachments: Egress Windos Non-Compliance Determination Form

**CONFIDENTIALITY NOTICE**

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.

CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM



**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: 2/28/11

APPEAL PROPERTY ADDRESS: 1081 ROSS

APPLICANT NAME: PUBLIC HEALTH (DAVID SCHWIDT) PHONE NUMBER: 651-266-1145  
*on behalf of ERIC PATRICK SCHWIDT*  
651-468-1962

PERMIT NUMBER: \_\_\_\_\_

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: <u>9.78 sqft</u>	DIFFERENCE FROM REQUIRED AREA: <u>COMPLIES</u>
WIDTH OF OPENING: <u>25"</u>	DIFFERENCE FROM REQUIRED OPENING: <u>COMPLIES</u>
HEIGHT OF OPENING: <u>22"</u>	DIFFERENCE FROM REQUIRED OPENING: <u>2"</u>
HEIGHT OF OPENING TO FINISHED FLOOR: <u>448"</u>	DIFFERENCE FROM MAXIMUM HEIGHT: <u>COMPLIES</u>

RECOMMENDATION (IF APPLICABLE): SEE EXHIBIT A

---



---



---



---



---

12/2009

FROM: \_\_\_\_\_

EXHIBIT A  
M ASSOCIATED MATERIALS  
I N C O R P O R A T E D

Select a Model

Model 0201  
Excelsior Double Hung

Top Sash Width	26.2500
Top Sash Height	27.3975
Bottom Sash Width	27.2500
Bottom Sash Height	23.1975
Top Glass Width	24.875
Top Glass Height	25.4000
Bottom Glass Width	26.5625
Bottom Glass Height	26.9600
Screen Width	23.6725
Screen Height	24.8200
Top Sash Weight (Plus 5 lb)	22 lb
Top Sash Weight (CJ)	26.80
Top Balance Size (Small)	23.48
Bottom Sash Weight	18.5
Bottom Balance Size (CJ)	21.41
Bottom Balance Size (Printed)	27.78
Glass Opening Width	25.0940
Glass Opening Height	22.0000
Gross Opening Area (sq. ft.)	3.1545

\* 25.8 x 57.6 = 1408 ÷ 144 = 9.78 sq ft

Min. W: 11	Max. W: 53
Min. H: 20	Max. H: 44
Max. III: 132	

Width: 28.5      Eased Size: 29.5

Height: 57.5      Eased Size: 57.5

Extremes: select Extinction      cc For Arch Top Models Only

Opening: Eased Size      Type: Standard

Screen: Full      Glass: Double Strength (Gmm)

AC Seal Operator