



CITY OF SAINT PAUL, MN

DEPARTMENT OF SAFETY AND INSPECTIONS

Steve Magner, Manager of Code Enforcement

Truth-in-Sale of Housing Report

This is a visual disclosure report based on the current City of Saint Paul Truth-in-Sale of Housing Evaluator Guidelines and is valid for one year from the date of issuance and for the owner named.

375 Jackson Street, Suite 220
Saint Paul, MN 55101-1806

Phone: 651-266-8989
Fax: 651-266-1919
Web: www.stpaul.gov/dsi


Property Address: 556 MINNEHAHA AVE E

Date of Evaluation: Nov 21, 2018

Date of Expiration: Nov 21, 2019

This report is intended to provide basic information to the home buyer and seller prior to the time of sale.

This report WILL NOT be used to enforce the requirements of the Legislative Code; however, it will be used to determine if there is compliance with the requirements for sale within the City of Saint Paul, MN.



MAJOR NOTIFICATIONS AND WARNINGS

For questions on these items, call the City's Information and Complaint Line at 651-266-8989

- Residential Type: Single Family Dwelling
- Smoke Detectors:
 - Smoke Detector Present: Y
 - Smoke Detector Properly Located: Y
 - Smoke Detector Hard Wired (required in Single Family Homes): Y
 - Smoke Detector Comments:
- Open Permits:

This property has the following open permits:

 - B - 18 046006 - VB #2 - CODE COMPLIANCE REPAIR - Inspected
 - PG - 18 050033 - -VENT & DRAIN 2ND FLOOR SHOWER - Inspected
 - M - 18 045770 - REPLACE (7) LEAKS IN SYSTEM, T - Active/Issued
 - PG - 18 116858 - SHOWER, SINK AND WATER CLOSET. - Active/Issued
- Registered Vacant Building
 - Visit www.stpaul.gov/dsi or call 651-266-8989

BELOW MINIMUM

Basement/Cellar

- Stairs and Handrails

Exterior Space

- Drainage (grade)
- Roof structure and covering

Hallways, Stairs and Entries

- Stairs and handrails to upper floors

H: Hazardous Condition	B: Below Minimum	C: See Comments	M: Meets Minimum
Y: Yes	N: No	NV: Not Visible	NA: Not Applicable

CITY OF SAINT PAUL TRUTH - IN - SALE OF HOUSING REPORT

Address: 556 MINNEHAHA AVE E

File Number: File#: 18-124687

Date of Evaluation: Nov 21, 2018

Owner: Michael P Downs

Zoning District: RT1

Client Name: Michael Downs

Present Occupancy: R-Single Family Dwelling

Client Contact: NA

Number of Units Evaluated: Single Family Dwelling

Evaluator Name: John Vruno Inspecta-Homes

Evaluator Contact: Work: 651-641-0641
stpvrano@inspectahomes.com

Basement/Cellar

- | | |
|-------------------------------------|---|
| 1. Stairs and Handrails | B |
| 2. Basement/Cellar Floor | M |
| 3. Foundation | M |
| 4. Evidence of Dampness or Staining | Y |
| 5. First Floor, Floor System | M |
| 6. Beams and Columns | M |

1. B - Handrail(s): Not continuous and lack return.B
- Head room less than 6 feet 8 inches.B- Door
opens into stairwell

4. C - Stains evident at walls

Electrical Services

- | | |
|-----------------------------------|-----------|
| 7a. Number of Electrical Services | 2 |
| 7b. Amps | 100 |
| 7c. Volts | 120 - 240 |

Basement Only

- | | |
|--|---|
| 8. Electrical service installation/grounding | M |
| 9. Electrical wiring, outlets and fixtures | M |

Plumbing System

- | | |
|--|---|
| 10. Floor drain(s) (basement) | M |
| 11. Waste and vent piping (all floors) | M |
| 12. Water piping (all floors) | M |
| 13. Gas piping (all floors) | M |
| 14. Water heater(s), installation | M |
| 15. Water heater(s), venting | M |
| 16. Plumbing fixtures (basement) | M |

Heating System(s)

The Evaluator is not required to operate the heating plant(s) except during the heating season, between October 15 and April 15.

- | | |
|--------------------------------|-----------|
| 17a. Number of Heating Systems | 1 |
| 17b. Type | Hot Water |

Report Rating Key (Where there are multiple rooms to a category, the Evaluator must specify the room to which a Comment is related)			
H: Hazardous Condition	B: Below Minimum	C: See Comments	M: Meets Minimum
Y: Yes	N: No	NV: Not Visible	NA: Not Applicable

17c. Fuel Gas

18. Installation and visible condition M

19. Viewed in operation N

(required in heating season)

20. Combustion venting M

21a. Additional heating unit(s): Type NA

21b. Additional heating unit(s): Fuel NA

21c. Installation and visible condition NA

21d. Viewed in operation NA

21e. Combustion venting NA

Kitchen

22. Walls and ceiling M

23. Floor condition and ceiling height M

24. Evidence of dampness or staining N

25. Electrical outlets and fixtures M

26. Plumbing fixtures M

27. Water flow M

28. Window size/openable area/mechanical exhaust M

29. Condition of doors/windows/mechanical exhaust M

Living and Dining Room(s)

30. Walls and ceiling M

31. Floor condition and ceiling height M

32. Evidence of dampness or staining N

33. Electrical outlets and fixtures M

34. Window size and openable area M

35. Window and door condition M

Hallways, Stairs and Entries

36. Walls, ceilings, floors M

37. Evidence of dampness or staining N

38. Stairs and handrails to upper floors B

38. B - Head room less than 6 feet 8 inches.B-Rise exceeds 8" and tread lengths less than 9"

39. Electrical outlets and fixtures M

40. Window and door conditions M

H: Hazardous Condition	B: Below Minimum	C: See Comments	M: Meets Minimum
Y: Yes	N: No	NV: Not Visible	NA: Not Applicable

Smoke Detectors

41a. Present	Y
41b. Properly Located	Y
41c. Hard-Wire	Y

Bathroom(s)

42. Walls and ceiling	M
43. Floor condition and ceiling height	M
44. Evidence of dampness or staining	N
45. Electrical outlets and fixtures	M
46. Plumbing fixtures	M
47. Water flow	M
48. Windows size/openable area/mechanical exhaust	M
49. Condition of windows/doors/mechanical exhaust	M

Sleeping Room(s)

50. Walls and ceilings	M
51. Floor condition, area and ceiling height	M
52. Evidence of dampness or staining	N
53. Electrical outlets and fixtures	M
54. Window size and openable area	M
55. Window and door condition	M

Enclosed Porches and Other Rooms

56. Walls, ceiling and floor condition	M
57. Evidence of dampness or staining	N
58. Electrical outlets and fixtures	M
59. Window and door condition	M

Attic Space

60. Roof boards and rafters	NV	60. C - Upper level finished, attic not viewed
61. Evidence of dampness or staining	NV	
62. Electrical wiring/outlets/fixtures	NV	
63. Ventilation	NV	

Exterior Space

64. Foundation	M	
65. Basement/cellar windows	M	
66. Drainage (grade)	B	66. B - Grade low /flat in areas

Report Rating Key (Where there are multiple rooms to a category, the Evaluator must specify the room to which a Comment is related)			
H: Hazardous Condition	B: Below Minimum	C: See Comments	M: Meets Minimum
Y: Yes	N: No	NV: Not Visible	NA: Not Applicable

67. Exterior walls M

68. Doors M

(frames/storms/screens)

69. Windows M

(frames/storms/screens)

70. Open porches, stairways and deck(s) M

71. Cornice and trim(s) M

72. Roof structure and covering B

72. B - Deteriorated roof

73. Gutters and downspouts M

74. Chimney(s) M

75. Outlets, fixtures and service entrance M

Garage(s)/Accessory Structure(s)

76. Roof structure and covering NA

77. Wall structure and covering NA

78. Slab condition NA

79. Garage door(s) NA

80. Garage opener(s) NA

81. Electrical wiring, outlets and fixtures NA

Fireplace/Woodstove

82. Number of Units NA

83. Dampers installed NA

84. Installation NA

85. Condition NA

Insulation

86a. Attic Insulation: Present NA

86b. Attic Insulation: Type NA

86c. Attic Insulation: Depth NA

87a. Foundation Insulation: Present N

87b. Foundation Insulation: Type NA

87c. Foundation Insulation: Depth NA

88a. Knee Wall Insulation: Present NA

88b. Knee Wall Insulation: Type NA

88c. Knee Wall Insulation: Depth NA

89a. Rim Joist Insulation: Present N

89b. Rim Joist Insulation: Type NA

89c. Rim Joist Insulation: Depth NA

General

Report Rating Key (Where there are multiple rooms to a category, the Evaluator must <u>specify the room</u> to which a Comment is related)			
H: Hazardous Condition	B: Below Minimum	C: See Comments	M: Meets Minimum
Y: Yes	N: No	NV: Not Visible	NA: Not Applicable

90. Carbon Monoxide Alarm M

General Comments

LEGAL NOTICES:

Chapter 189 of the Saint Paul Legislative Code requires all single family, duplex, condo, townhouse and co-op homes for sale in the city to have a Truth-in-Sale of Housing disclosure report prepared and available to prospective buyers. A Truth-in-Sale of Housing disclosure report must be done for Contract-For-Deed sales.

A Truth-in-Sale of Housing (TISH) Disclosure Report in the City of Saint Paul is intended to provide basic information to the home buyer and seller prior to the time of sale. Failure to obtain a Truth-in-Sale of Housing disclosure report or failure to make that disclosure report available to prospective buyers, is a violation of law and is punishable as a misdemeanor carrying up to 90 days in jail and/or a \$1,000.00 fine.

A valid Truth-in-Sale of Housing disclosure report must be conspicuously displayed at the premises for all prospective buyers. TISH disclosure reports are also available online: <https://online.stpaul.gov/web/portal/public-search>

- This report WILL NOT be used to enforce the requirements of the Legislative Code; however, this evaluation form will be used to determine if there is compliance with the requirements for a hard-wired smoke detectors.
- This TISH report is based on the current Truth-in-Sale of Housing Evaluator Guidelines and is based upon different standards than the lender, Federal Housing Administration (FHA) or Veterans Administration (VA).
- This TISH is not warranted, by the City of Saint Paul nor by the evaluator for the condition of the building component, nor of the accuracy of this report.
- This TISH report covers only the items listed on the form and only those items visible at the time of the evaluation.
- The Evaluator is not required to operate the heating plant (except during the heating season), use a ladder to observe the condition of the roofing, disassemble items or evaluate inaccessible areas.
- This TISH report is valid for one year from the date of issue and only for the owner named on this report.
- If this building is used for any purpose other than a single family dwelling, it may be illegally zoned. To help you determine legal uses under the zoning ordinance, contact the Zoning Administrator at (651) 266-9008.
- Automatic garage doors should reverse upon striking an object. If it does not reverse, it poses a serious hazard and should be repaired or replaced immediately.
- All single family residences in Saint Paul must have at least one smoke detector connected to the electrical system (hard-wired). The detector must be located near sleeping rooms. For more information call Fire Prevention, (651)228-6230. (Saint Paul Legislative Code, Chapter 58.)
- Rainleaders connected to the sanitary sewer system must be disconnected. For more information call Public Works, Sewer Utility, and (651)266-6234.
- A house built before 1950 may have lead paint on/in it. If children ingest lead paint, they can be poisoned. For more information call Ramsey County Public Health, (651)292-6525.
- Neither the City of Saint Paul nor the Evaluator is responsible for the determination of the presence of airborne particles such as asbestos, noxious gases such as radon, or other conditions of air quality that may be present, nor the conditions which may cause the above.

Questions regarding this report should be directed to the evaluator. If you desire a reinspection and amended report, please contact your evaluator. They will perform a reinspection and file an amended report with the City of Saint Paul. The TISH evaluator may charge for this reinspection. Complaints regarding this report should be directed to Department of Safety and Inspections, Truth-in-Sale of Housing Program, Phone 651-266-8989.

Evaluator Statement:

I hereby certify I prepared this report in compliance with the Saint Paul Evaluator Guidelines, City of Saint Paul City Ordinance 189 and all other applicable policies and procedures of the Truth-in_Sale of Housing Board. I have utilized reasonable and ordinary care and diligence and I have noted all conditions found that do not conform to the minimum standards of maintenance. The report covers only those problems listed and reasonably visible at the time of my evaluation and does not warrant future useful life of any house component or fixture. I have included all required information pages with this report.

Evaluator Name: John Vruno Inspecta-Homes

Phone: Work: 651-641-0641

Evaluation Date: Nov 21, 2018