



APPLICATION FOR APPEAL

RECEIVED

OCT 12 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☐ Walk-In OR ☒ Mail-In

YOUR HEARING Date and Time:

Tuesday, 10-25-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1338 Reaney ^{Ave E} City: St. Paul State: MN Zip: 55106

Appellant/Applicant: MP Systems Inc Email mpsystems@home@hotmail.com

Phone Numbers: Business 763-572-3707 Residence — Cell 651-755-0723

Signature: Mark J. Pierce Date: 10/12/11

Name of Owner (if other than Appellant): Mark J. Pierce

Address (if not Appellant's): _____

Phone Numbers: Business 763-572-3707 Residence _____ Cell 651-755-0395

What Is Being Appealed and Why? *Attachments Are Acceptable*

- ☐ Vacate Order/Condemnation/Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

2 windows in home
due to size + permit
issue.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 11, 2011

APPEAL PROPERTY ADDRESS: 1338 REANEY AVE

APPLICANT NAME: MP SYSTEMS INC

PHONE NUMBER: 651-755-0723

PERMIT NUMBER: 11 258304

TYPE OF WINDOW Casement

NUMBER OF WINDOWS TWO

Total Glazed Area Minimum 5 Square Feet	7.2 sq. ft.	Difference from Required Area	+1.5 sq. ft.
Width of Opening Minimum 20 Inches	19"	Difference from Required Opening	-1"

Height of Opening Minimum 24 Inches	55"	Difference from Required Opening	+31"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	

COMMENTS:

Reviewed by: David Nelson